

MODEL: **MAS.BR.BEKO**

SIZE: **60,8 x 60,8 (F)**

PRODUCT TYPE: **GLAZED CERAMIC TILES**

GROUP: **B Ib**

DATE: 20/11/18

TESTS CARRIED OUT	RESULTS	
UNE-EN ISO 10545-2 DIMENSIONS AND SURFACE QUALITY		CONFORMS TO STANDARD
UNE-EN ISO 10545-3 WATER ABSORPTION	AVERAGE VALUE (%)	0,5 % - 3 %
UNE-EN-ISO 10545-4 MODULUS OF RUPTURE	BREAKING STRENGTH (N)	1.400 - 1.500 N
	MODULUS OF RUPTURE (N / mm ²)	35 - 45 N/mm ²
UNE-EN ISO 10545-9 RESISTANCE TO THERMAL SHOCK	THERMAL SHOCK	RESISTS
UNE-EN ISO 10545-11 CRAZING RESISTANCE	RESULTS	RESISTS
UNE-EN ISO 10545-12 FROST RESISTANCE	RESULTS	RESISTS
UNE-EN ISO 10545-13 CHEMICAL RESISTANCE	AMMONIUM CHLORIDE 100 g/l	A
	SODIUM HYPOCHLORITE 20 mg/l	A
	HYDROCHLORIC ACID 3 %	CONFORMS TO STANDARD
	CITRIC ACID 100 g/l	
UNE-EN ISO 10545-14 STAIN RESISTANCE	POTASSIUM HYDROXIDE 30 g/l	
	GREEN AGENT IN LIGHT OIL	5
	IODINE SOLUTION IN ALCOHOL	5
	OLIVE OIL	5

OBSERVATIONS:

LABORATORY :



AZULEJOS FOSET, SLU, Camino del Palmeral, 10
12200 ONDA (Castellón) ESPAÑA